



- NOTES:
- 1- HEIGHTS SHOWN ARE PVP STANDARDS PUMP CENTERLINE HEIGHTS CAN BE RAISED OR LOWERED.
  - 2- SWITCHES AND DAMPENERS ARE OPTIONAL. CHECK BUILD SHEETS FOR EQUIPMENT SUPPLIED.
  - 3- FLEX JOINTS NOT RECOMMENDED
  - 4- WHEN INSTALLING PUMP KEEP AREA UNDER PUMP CLEAR FOR MAINTENANCE
  - 5- SUCTION AND DISCHARGE THE PUMP KEEP AREA UNDER PUMP CLEAR FOR MAINTENANCE

TOLERANCES

FRACT.	± 0.25
DEC.	± 0.25
ANG.	± 0.5

DESCRIPTION	DATE	BY
REVISION HISTORY		

CUSTOMER:	PROJECT: 10" Duplex
LOCATION:	
DRAWING NO.:	PVD519
SHEET 1 OF 1	REV. A

FOR THE PROPERTY OF  
**PENNSYLVANIA VALLEY PUMP CO., INC.**  
 998 EASTON ROAD - WARRINGTON, PA 18976  
 PHONE: (215) 343-8750 FAX: (215) 343-8753

ALL INFORMATION CONTAINED IN THIS DOCUMENT IS SOLELY CONFIDENTIAL AND PROPRIETARY TO PVP. NO USER, COMPRESSOR, OR OTHER PARTY SHALL BE PERMITTED TO REPRODUCE OR TRANSMIT IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF PVP.

SCALE: 1/2" = 1"  
 DATE: 7/11/08  
 DESIGNED BY: T. Lamson