



NOTES:

- 1- HEIGHTS SHOWN ARE PVP STANDARDS PUMP CENTERLINE HEIGHTS CAN BE RAISED OR LOWERED.
- 2- SWITCHES AND DAMPENERS ARE OPTIONAL. CHECK BUILD SHEETS FOR EQUIPMENT SUPPLIED.
- 3- FLEX JOINTS NOT RECOMMENDED
- 4- WHEN INSTALLING PUMP KEEP AREA UNDER PUMP CLEAR FOR MAINTENANCE
- 5- TO REMOVE BELT GUARD, 30-INCHES IS REQUIRED ABOVE THE PUMP. COVER CAN BE SPLIT TO BE REMOVED HORIZONTALLY

NOTES			
MATERIAL: -----			
REV	DESCRIPTION	DATE	BY
0	INITIAL RELEASE	9/16/2020	ABB
REVISION HISTORY			

THIS DRAWING AND ALL INFORMATION IS THE PROPERTY OF

**PENN VALLEY PUMP CO., INC.**

998 EASTON ROAD - WARRINGTON, PA 18976

PHONE : (215) 343-8750    [www.pennvalleypump.com](http://www.pennvalleypump.com)

ALL INFORMATION CONTAINED IN THIS DOCUMENT IS BOTH CONFIDENTIAL AND PROPRIETARY TO PVP. NO LICENSE, EXPRESSED OR IMPLIED, UNDER ANY PATENT, COPYRIGHT, OR TRADE SECRET IS GRANTED OR IMPLIED BY THE CONVEANCE OF THIS DOCUMENT. NO PART OF THIS DOCUMENT MAY BE REPRODUCED, TRANSMITTED, TRANSCRIBED, STORED IN A RETREVAL SYSTEM, TRANSLATED TO ANY LANGUAGE OR COMPUTER LANGUAGE, IN ANY FORM BY ANY MEANS ELECTRONIC, MECHANICAL, OR OTHERWISE.

CUSTOMER: Penn Valley Pump

LOCATION: Internal

TITLE: 3DDSX22 Piggy Back

SCALE: N/A

DATE: 9/17/2020

DR. BY: -

PLOT DATE:

DRAWING NO. PVD763

SHEET 1 OF 1